



QPS Evaluation Services Inc
Testing, Certification and Field Evaluation Body
Accredited in Canada, the USA, and Internationally

File
LR1049

CERTIFICATE OF COMPLIANCE
(ISO TYPE 3 CERTIFICATION SYSTEM)

Issued to	Amphenol EEC, Inc.
Address	4050 N Rockwell Street Chicago, IL 60618 USA
Project Number	LR1049-3R1
Product	Electrical Plugs and Receptacles
Model Number	HDE-1-22-33-444444-55-6666-7-8-9-10 HDS-1-22-33-444444-55-6666-7-8-9-10 EFP-1-22-33-444444-55-6666-7-8-9-10 EFPV-1-22-33-444444-55-6666-7-8-9-10
Ratings	Class I, Div 2 Gr ABCD, T1-T6 Ex nA IIC, T1-T6 Class I Zone 2, AEx na IIC, T1-T6 Ta=-40°C to +40°C, -40°C to +50°C, -40°C to +65°C 600 V, 1000A Max, 106.1W* Max *denotes dissipated wattage
Applicable Standards	CSA C22.2 No. 182.3-1987; CSA C22.2 No. 213-1987; CSA C22.2 No. 60079-0 -12; CSA C22.2 No. 60079-15-12; UL 1977 2nd edition; ISA/ANSI 60079-0 -2009; ISA/ANSI 60079-15-2009; ISA 12.12.01 -2011
Factory/Manufacturing Location	4050 N Rockwell Street, Chicago, IL 60618 USA

Statement of Compliance: The products identified in this Certificate and described in the Report covered under the above referenced project number have been investigated and found to be in compliance with the relevant requirements of the above referenced standards. As such, they are eligible to bear the QPS Certification Mark shown below, in accordance with the provisions of QPS's Service Agreement.



Issued By: **Dave Adams, P.Eng.**
 Manager, Hazardous Locations Dept. [Ex Equipment]

Signature: 

Date: July 26, 2016